

Status:     Current     Issue No: 2     Issue 1 (2017-12 Issue 0 (2016-09)       Date of Issue:     2020-08-26       Applicant:     Transus Instruments BV Bioesemian 4 3897 UX Zeewolde Netherlands       Equipment:     Utrasonic Flowmetor type UIM Sories Flowmeter       Optional accessory:     Type of Protection:       Type of Protection:     Ex is       Marking:     Ex is IIC T4 Ga		IEC Certification	L ELECTROTECHNICAL COMMISSION on System for Explosive Atmospheres details of the IECEx Scheme visit www.iecex.com	
Status:     Curront     Issue No: 2     Issue 0 (2016-09       Date of Issue:     2020-08-26       Applicant:     Transus Instruments BV Biggesemilan 4 3897 LN Zeewoide Netherlands       Equipment:     Ultrasonic Flowmeter type UIM Series Flowmeter       Optional accessory:     Transumer in the series flowmeter       Type of Protection:     Ex ia       Marking:     Ex ia IIC T4 Ga	Certificate No.:	IECEx DEK 16.0007X	Page 1 of 5	Certificate history:
Applicant:       Ransus instruments BV Biosemiaan 4 agouges and biosemiaan 4 biosemiaan 4 biose	Status:	Current	Issue No: 2	Issue 1 (2017-12-12) Issue 0 (2016-09-21)
Bioesemian 4 387 Equipment: Utrasonic Flowmeter type UIM Series Flowmeter Optional accessory: Type of Protection: Ex ia Marking: Ex ia IIC T4 Ga Marking: Ex ia IIC T4 Ga Approved for issue behalf of the IECEx Critification Body: Position: R. Schuller Position: Critification Manager Signature: Signature: Signature: Signature: S	Date of Issue:	2020-08-26		
Optional accessory:         Type of Protection:       Ex la         Marking:       Ex la IIC T4 Ga             Approved for issue urbenali of the IECEx       R. Schuller             Position:       Certification Manager         Signature:       Certification Manager	Applicant:	Bloesemlaan 4 3897 LN Zeewolde		
Type of Protection: Ex ia   Marking: Ex ia IIC T4 Ga     Approved for issue on behalf of the IECEx R. Schuller   Position: Certification Manager   Signature: (for printed version)   Date: Ex is in the instant of the i	Equipment:	Ultrasonic Flowmeter type UI	M Series Flowmeter	
Marking: Ex is IIC T4 Ga Approved for issue on behalf of the IECEx Certification Body: Position: Position: Signature: (for printed version): Date:	Optional accessory:			
Approved for issue on behalf of the IECEx R. Schuller Certification Body: Position: Certification Manager Signature: (for printed version) Date:	Type of Protection:	Ex ia		
Certification Body: Position: Certification Manager Signature: (for printed version) Date:	Marking:	Ex ia IIC T4 Ga		
Certification Body: Position: Certification Manager Signature: (for printed version) Date:				
Signature: (for printed version) Date:		n behalf of the IECEx	R. Schuller	
(for printed version) Date:	Position:		Certification Manager	
<ol> <li>This certificate and schedule may only be reproduced in full.</li> <li>This certificate is not transferable and remains the property of the issuing body.</li> <li>The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.</li> </ol>	2. This certificate is not	t transferable and remains the property of		

**DEKRA Certification B.V.** Meander 1051 6825 MJ Arnhem **Netherlands** 

# DEKRA



Certificate No .:	IECEx DEK 16.0007X	Page 2 of 5	
Date of issue:	2020-08-26	Issue No: 2	
Manufacturer:	Transus Instruments BV Bloesemlaan 4		
	3897 LN Zeewolde Netherlands		
Manufacturing			
locationa			

locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

#### STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements Edition:7.0

IEC 60079-11:2011 Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

This Certificate does not indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

#### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

NL/DEK/ExTR16.0010/02

Quality Assessment Report:

NL/DEK/QAR16.0009/02



Certificate No.: **IECEx DEK 16.0007X** 

Date of issue:

Page 3 of 5

Issue No: 2

#### EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

2020-08-26

The UIM Series Flowmeter consists of an Electronic Unit and a flowmeter body. The electronic unit consists of a main electronic board, various optional I/O boards, an LC display and keypad, and is housed in an aluminium or stainless steel enclosure. The electronic unit connects to up to eight ultrasonic transducers and an optional pressure and/or temperature sensor that may be mounted in the flowmeter body.

Ambient temperature range -40 °C to +60 °C.

Process temperature range -40 °C to +80 °C. Or higher than 80 °C, provided that the Electronics Unit is mounted at sufficient distance from the process pipe to negate the influence of heating from the process. The transducers may be connected by cabling of up to 3 meter length.

The maximum temperature process temperature for each temperature class shall then be limited per the table below.

Temperature class	Maximum process temperature
Т1	445 °C
Т2	295 °C
ТЗ	195 °C
Т4	130 °C

#### **Electrical data**

For connection details and electrical data, refer to the control drawing 01 0198 (see attachment).

#### Installation instructions

The instruction manual and the control drawing 01 0198 shall be followed in detail to assure proper and safe operation.

#### SPECIFIC CONDITIONS OF USE: YES as shown below:

The transducer must be installed in an enclosure that protects the front face of the transducer against impact. This additional enclosure may be the process pipe.

Precautions shall be taken to minimize the risk from electrostatic discharge of painted parts.

For Flowmeter electronic enclosures made of aluminium only:

If it is mounted in an area where the use of EPL Ga equipment is required, it must be installed such, that, even in the event of rare incidents, ignition sources due to impact and friction sparks are excluded.



IECEx DEK 16.0007X Certificate No .:

Date of issue:

Page 4 of 5

Issue No: 2

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

1. Assessed per IEC 60079-0 Ed. 7 2. New Dual RS485 Option Board

Minor constructional changes
 Optional remote installation with higher process temperature

2020-08-26



Certificate No .:

IECEx DEK 16.0007X

Date of issue:

. . . .

2020-08-26

Page 5 of 5 Issue No: 2

### Additional information:

Nomenclature

UIM Electronics assembly model number									
UIME-AB-C-DEFGH									
A	x	Number of paths (1 to 4)							
В	x	Application type							
С	x	Meter size							
D - SLOT1	0 1 2 3	Not installed RS485 Option board (01-0020) RS485 IO 420mA option board (01-0202) Dual RS485 IO option board (01-0251)							
E - SLOT2	0 1 2 3	Not installed P/T option board (01-0022) 420mA HART option board (01-0203) Dual RS485 IO option board (01-0251)							
F – LCD	0 1 2	Not installed Installed SS316 enclosure with display/keypad							
G	1 2	M20 cable gland entries 1/2" NPT cable gland entries							
Н	x	options, not affecting explosion safety							

#### Annex:

224254600.Attachment 1.pdf

I	2				3			4				5	6
	1												
FUNCTION	TERMINALS	Ui V	li m (	Pi mW	Ci µF	Li mH	Uo V	lo mA	Po mW	Co µF	Lo mH		UIM Electronics assembly model no
STANDARDI/O		v	mA	mvv	μг	100	v	IIIA	mvv	μr		UIME-AB-C	-DEEGH
	PWR0+	20	100	670	0.02								
LOOP POWER SUPPLY	PWR0-	29	100	670	0.03	0.3						Α	x Number of paths (1 to 4)
REQUECY/PULSE OUTPUT	D0A	29	100	670	0.03	0.3						В	x Application type
	D0 B	25	100	0/0	0.03	0.5						С	x Meter size
SLOT 1, RS485 Option board (01-002												D - SLOT 1	0 Not installed
POWERSUPPLY	PWR1+	28	100	670	0.03	0.3							1 RS485 Option board (01-0020)
	PWR1-											-	2 RS48510 420mA option board
35485 COIVIVIUNICATION	D1A D1B	4.2	250	250	20	neg	4.12	150	150			E - SLOT 2	3 Dual RS48510 option board (01- 0 Not installed
	D1B D2A												1 P/T option board (01-0022)
RECITE V/PTTSE CITIPITI	D2 B	15	100	250	0.03	0.02							2 420mA HART option board (01-
	D3A											1	3 Dual RS48510 option board (01-
REQUECY/PULSE OUTPUT	D3 B	15	100	250	0.03	0.02						F - LCD	0 Not installed
SLOT 1, RS485 IO 420mA option bo	ard (01-0202)											]	1 Installed
LOOP POWER SUPPLY / 420mA	PWR1+	29	100	670	0.03	0.3							2 SS316 enclosure with display/ke
	PWR1-		100	0/0	0.05	0.5						G	1 M20 cable gland entries
RS485 COMMENTCATION	D1A	4.2	250	250	20	neg	4.12	150	150				2 1/2" NPT cable gland entries
	D1B										ļ	H	x options, not affecting explosion
-REQUECY/PULSE OUTPUT	D2 A	15.5	100	250	0.03	0.02							
	D2 B												THE UIM MODEL NUMBER ON THE NA
RECHTECY/PHINE CHTPTH	D3 A D3 B	15.5	100	250	0.03	0.02						ENCLOSU	RE AND REFER TO TABLE FOR SPECIFIC
SLOT 1, Dual RS485 IO option board												┥ └───	PARAMETERS
	PWR1+											-	
OOP POWER STIPPTY //L 20mA	PWR1-	29	100	670	0.03	0.3							
RS485 COMMUNICATION - PORT 1	D1A	4.2	250	250	20	neg	4.12	150	150			1	
13485 COMMONICATION - FORT I	D1B	4.2	2.50	250	20	neg	4.12	150	100				
REQUELT/PULSE OUTPUT	D2 A	15.5	100	250	0.03	0.02							
	D2 B											_	
REQUECY/PULSE OUTPUT	D3A	15.5	100	250	0.03	0.02							
	D3B											-	
RS485 COMMUNICATION - PORT 2	D4A D4B	4.2	250	250	20	neg	4.12	150	150				
	PRESS		REFER TO S								<u> </u> т	-	
PRESSURE / TEMPERATURE	TEMP	1	ner en ros		ABLELENG								
SLOT 2, P/T option board (01-0022)					1					1		1	
	PRESS1		1	I		!	1	1		ļ	!	1	
	PRESS2	İ											
PRESSURE	PRESS3	]											
	PRESS4		REFER TO S	SAFETYINS	TRUCTION	S FOR INTE	RCONNECT	TION TO A	PROVED E	QUIPMEN	Т		
	TEMP1			C	ABLE LENG	ТН NOT ТО	EXCEED 2	meter (6.7	ft)				
TEMPERATURE	TEMP2	-											
	TEMP3	-											
	TEMP4		1		1							4	
	(01-0203)											4	
SLOT 2,420mA HART option board												1	
SLOT 2,420mA HART option board	LPWR2+	29	100	670	0.03	0.3							
	LPWR2+ LPWR2-	29	100	670	0.03	0.3							

Ex ia IIC T4 Ga -40°C ≤ Tamb ≤ +60°C IECEx DEK16.0007X

1

2

С

D

Е


**CE**0344 II 1 G Ex ia IIC T4 Ga -40ºC ≤ Tamb ≤ +60ºC  $\langle Ex \rangle$ 

3

DEKRA 16ATEX0014 X

4

5	5			6		7			8		
_	<b></b>										
_		UIME	lectron	ics assembly mode	el number						
	UIME-A	B-C-DEFGH									A
				(1++ 1)							
-	A B		plicatio	f paths (1 to 4) n type							
	C		eter size								
	D - SLO	Γ1 Ο No	ot instal	ed							
				ion board (01-002							
4				20mA option bo							
	E - SLOT		ual RS48 ot instal	510 option board	(01-0251)						
-	2 - 3201			board (01-0022)							
				ART option board	(01-0203)						В
				510 option board	(01-0251)						
4	F - LCD		ot instal	ed							
-			stalled	osure with displa	/kowood						
	G			gland entries	улкеурай						
1	ľ			able gland entries	s						
	н			ot affecting explo							
_				NUMBER ON THE							
	ENCLO	SURE AND	REFERT	D TABLE FOR SPEC	IFIC INTRINSIC	SAFETY					С
-				PARAMETERS							
4											
-											
											D
4											
-											
+											
1											
	OTHERWISE SPECIFIED:				DEBUR AND		DO NOT SCALE DRA	WING	REVISION DWG	A-08	
URFAC	SIONS ARE IN MILLIMETE CE FINISH: Ra<0.8				BREAK SHARP EDGES		DO NOT SOME DIV		REVISION DWG		
OLERA	ANCES: ACC. TO ISO/DI	IN 2768-MK							REVISION PRT/ASM		
						TITLE					
						TITLE:	$\sim$ '	1 1	•		
1	<b>RAN</b>	ISUS	5				Contr	ol dro	wing		
	- 10 C	MENTS					ATF	X/IEC	Fx		
							7 \ 1 L				
DA 14/2	NAME	SIGNATURE	DATE	MATERIAL:		DWG NO.	∩1	_019	2	A3	3
RAWN			3-6-2020	-			UI		0		
	DATE PRINTED: 18-6	-2020	1	WEIGHT:		SCALE:1:1		SHEET	1 OF 4		



	1	2	3	4	5	6	
A	REAR VIEW						
					UIM FLOWMETER 420mA HART option board	HAZARDOUS	NON-F
В				Ui = 2 Ii = 10 Pi = 6 Li = 0. Ci = 0.	(01-0203) 9V DmA LPWR2+ 'OmW LOOP SUPPLY 8mH LPWR2- 	AREA	
	SLO	DT 2		Ui = 2 li = 10	OmA 4.20m A LOOP / PWR1+ 0		
С				Pi = 6 Li = 0. Ci = 0. Uo = 4 lo = 15 Po = 1 Li = ne Ci = 20 Ui = 4. li = 25 Pi = 25 Ui = 12 Ui = 12 Li = 10	OTW     SUPPLY       BmH     PWR1-       03μF     isolated       .12V     0mA       00mA     D1 A       50mW     RS485       gligible     D1 B       μF     optically isolated       2V     0mA       0mW     .5V		
D	SLOT 1 FITTED W	/ITH RS485 420mA option b	oard	Pi = 25 Li = 0.1 Ci = 0. Ui = 12 li = 10 Pi = 25 Li = 0.1	02mH D2 B(-) 03µF optically isolated open collector .5V 0mA D3 A(+) 0mW FREQ/PULSE		
E	SLOT 2 FITTED W	/ITH 420mA HART option bo		Ci = 0.			



**Ching!** EXPLOSION HAZARD SUBSTITUTION OF COMPONENTS MAY IMPAIR INTRINSIC SAFETY

3

4

Only for interconnection with Exi or [Exi] Associated equipment.


2

Comply with EU directive 2014/34/EU And EN/IEC 60079-0 EN/IEC60079-11

INSTALL PER IEC 60079-14


1

UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN MILLIMETERS SURFACE FINISH: R0<0.8 TOLERANCES: ACC. TO ISO/DIN 2768-mK



8

7



	ZARDOUS REA	ASSOCI	ATED E	QUIPMENT		
		 -•• + -•• -	Po <= 67 Lo >= 0.3	<= 100mA		
		 -Ф A(+) -Ф B(-)	Ui >= 4.1 Ii >= 150 Pi >= 150 Lo >= L(c Co >= 20 Uo <= 4. Io <= 250 Po <= 25	mA DmW able) μF + C(cable) 2V DmA		В
		· •• + •• -	Uo/Voc - Io <= 100 Po <= 25 Lo >= 0.0	 <= 15.5V )mA		
		 -• + -• -	lo <= 10 Po <= 25 Lo >= 0.0			С
		 	Ui >= 4.1 li >= 150 Pi >= 150	mA )mW		
		-Ф В(-)	Lo >= L(c Co >= 20 Uo <= 4. Io <= 250 Po <= 25	μF + C(cable) 2V DmA		D
1AY IN	1PAIR INTRINSIC	SAFETY				
AND SHARP	DO NO	T SCALE DRAWING		REVISION DWG	A-08	
				REVISION PRT/ASM		
	ПТLE: <b>(</b>	Contro ATE	ol dr X/IE	awing CEx		
	DWG NO.	01_(	019	8	A3	3
	SCALE:1:1		SHEET 4	OF 4		

А